

ANJI YIKE DECORATION MATERIAL TECHNOLOGY CO., LTD

TEST REPORT

SCOPE OF WORK

Woven vinyl flooring

REPORT NUMBER

191106006SHF-004

TEST DATE(S)

2019-11-06 - 2019-11-21

ISSUE DATE

2019-11-21


PAGES

5

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10k(May 1, 2019)

© 2019 INTERTEK



Test Report

Statement

- 1.This report is invalid without company's special seal for testing on assigned page.
- 2.This report is invalid without authorized person's signature.
- 3.This report is invalid where any unauthorized modification indicated.
- 4.Don't copy this report in partial (except full copy) without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.Any holder of this document is advised that this report is for the exclusive use of Intertek's Customer and is provided pursuant to the agreement between Intertek and its Customer. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. This report was made with due care within the limitation of a defined scope of work and on the basis of information, materials and instructions received from the Customer or its nominated third parties. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. The tests results are not intended to be a recommendation for any particular course of action. Customer is responsible for acting as it sees fit on the basis of such results.
- 6.Intertek's written consent is required to use Intertek's name or logo on the object, product or service being tested. The observations and test results in this report relate only to the sample under test. This report alone does not indicate that the item, product or service has passed any Intertek certification program.

Test Report

Issue Date: 2019-11-21

Intertek Report No. 191106006SHF-004

Test Items, Method and Results:

Test Item: Formaldehyde content test

Test Method: As per ASTM D6007-14 small scale chamber method, formaldehyde content was detected by UV-VIS spectrophotometer.

Test condition:

Chamber type:	0.225 m ³ stainless steel chamber
Climatic conditions:	25°C, 50% R.H.
Air exchange rate:	0.5 h ⁻¹
Loading factor:	0.95 m ² /m ³
Test result:	ND

Note:

1. ppm = parts of formaldehyde per million parts air
2. Detection limit = 0.02 ppm
3. ND = not detected
4. The sample was conditioned at 24±3 °C, 50±5% relative humidity for seven days before the testing.
5. Test location: Central Chemical Lab of Intertek Testing Services Ltd., Shanghai
Address: Block B, Jinling Business Square, No. 801, Yi Shan Road, Shanghai, China

Test Report

Issue Date: 2019-11-21

Intertek Report No. 191106006SHF-004

Appendix A: Sample Received Photo



Revision:

NO.	Date	Changes	Author	Reviewer
191106006SHF-004	2019-11-21	First issue	Jackie Zhou	Flora Fan